


Job Name: _____ Submitted By: _____ Date: _____
 _____ Spec. Section: _____
 Job Location: _____ Engineer/Architect: _____
 _____ Approval: _____ Date: _____



Setting instructions:

The Oventrop automatic air vent is used for the elimination of air which is generated during operation of the heating system.

The 1/2-inch automatic air vent can be cleaned and replaced under working conditions without pressure discharge from system because of the automatic shut-off device.

The air vent must be installed vertically. The air vent is a float type.

Body made of brass.

Temperature range: 32°F to 240°F

Maximum pressure: 150 psi

Maximum glycol concentration: 30%

Model

1/2 inch air vent 108 83 84

| Item no. | G | A | Automatic shut-off device |
|-----------|-------------------|-----|---------------------------|
| 108 83 84 | 1/2 inch male NPT | 3.8 | With |