

We, **Oventrop GmbH & Co. KG**

Paul-Oventrop-Str.1
D-59939 Olsberg

hereby declare at sole responsibility that the following products to which this declaration refers, correspond to the standards and technical specifications

DIN EN 13828, DIN 50930- 6

Product


Ball valve for potable water "Optibal TW"

Item no.	DN [mm]	Max. operating pressure p_s	Operating temperature range t_s	CE- Marking
420 88 52	15	10 bar (PN 10)	0°C up to 90°	No
420 88 53	15			
420 88 54	20			
420 88 55	25			
420 88 56	32			
420 88 57	40			
420 88 58	50			

Monitoring quality management system:
Surveillance during production:

DQS 000211 QM
OVENTROP

Olsberg, 09.12.2010

i.V. 
Dr. Ing. Foitzik
Technical director

i.A. 
Dipl.-Ing. Coerdts
Project manager