

We, **Oventrop GmbH & Co. KG**

Paul-Oventrop-Str.1
D-59939 Olsberg

hereby declare at sole responsibility that the following products to which this declaration refers, correspond to the standards and technical specifications

DIN EN 13828, DIN 50930- 6

Product

Ball valve for potable water "Optibal TW"

Item no.	DN [mm]	Max. operating pressure p _S	Operating temperature range t _S	CE- Marking
420 88 04	15	10 bar (PN 10)	0°C up to 90°C	No
420 88 06	20			
420 88 08	25			
420 88 10	32			
420 88 12	40			
420 88 16	50			
420 88 20	65			
420 88 24	80			
420 89 04	15			
420 89 06	20			
420 89 08	25			
420 89 10	32			
420 89 12	40			
420 89 16	50			

Monitoring quality management system:
Surveillance during production:

DQS 000211 QM
OVENTROP

Olsberg, 09.12.2010

i.V. 
Dr. Ing. Foitzik
Technical director

i.A. 
Dipl.-Ing. Coerdts
Project manager