

We,

Oventrop GmbH & Co. KG

Paul-Oventrop-Str. 1

D-59939 Olsberg

Hereby declare at sole responsibility that the following products to which this declaration refers, correspond to the standards and technical specifications

DIN EN 12514-2 : 2000-05

Product

Double ball foot valve

Item no.	DN [mm]	Max. Working pressure p_s	Working temperature range t_s	CE-marking
203 00 03	DN 10	suction pressure *)	0°C up to +40°C	No
203 00 04	DN 15			
203 00 06	DN 20			
203 00 08	DN 25			

*) Max. permissible test pressure: up to 6 bars

The Double ball foot valves are tested by TÜV Rheinland in accordance with the above mentioned standard and specification. According to the German Construction Regulation List A Part 1 Edition 2004/1 ser. no. 15.41 the products / packing are marked with the sign Ü (ÜHP-method).

Monitoring system:

DQS 000211 QM


Olsberg, 15.12.2011

i. V.



Dr. Foitzik
Technical director

i. A.



Dipl.-Ing. Pöges
Project manager