

We, **Oventrop GmbH & Co. KG**

Paul-Oventrop-Str. 1  
D-59939 Olsberg


hereby declare at sole responsibility that the following products to which this declaration refers, correspond to the standards and technical specifications  
**DIN 16892, DIN 16893, DIN EN ISO 15875, DIN 4726, DIN EN 1264-4**


Product

**PE-Xc plastic pipes "Copex"**

| Item no.  | Pipe dimensions [mm] | Max. operating pressure p <sub>s</sub> | Working temperature range t <sub>s</sub> | CE-marking |
|-----------|----------------------|----------------------------------------|------------------------------------------|------------|
| 140 00 51 | 14 x 2               | 6 bar (PN 6)<br><br>10 bar (PN 10)     | bis 90°C<br><br>bis 60°C                 | No         |
| 140 00 52 |                      |                                        |                                          |            |
| 140 00 54 |                      |                                        |                                          |            |
| 140 01 51 | 16 x 2               |                                        |                                          |            |
| 140 01 52 |                      |                                        |                                          |            |
| 140 01 54 |                      |                                        |                                          |            |
| 140 02 51 | 17 x 2               |                                        |                                          |            |
| 140 02 52 |                      |                                        |                                          |            |
| 140 02 54 |                      |                                        |                                          |            |
| 140 03 52 | 20 x 2               | 6 bar (PN 6)                           | bis 90°C                                 |            |
| 140 03 54 |                      | 8 bar (PN 8)                           | bis 70°C                                 |            |

Olsberg, 15.09.2011

i.V.   
Dr. Foitzik  
Technical director

i.A.   
Dipl.-Ing. Wilmes  
Project manager