CERTIFICATE

Product certificate
K43256/04

Issued *2017-07-15*

Replaces *K43256/03*

Thermostatic regulating valves

STATEMENT BY KIWA
With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Oventrop GmbH & Co. KG

as specified in this product certificate and marked with the Kiwa ®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline **BRL-K14003** "Thermostatic regulating valves" **dated 01-02-2012**

Luc Leroy
Kiwa

Publication of this certificate is allowed.
Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

2871/170315

Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company
Oventrop GmbH & Co. KG
Paul-Oventrop-Straße 1
59939 OLSBERG
Germany
Tel. +49 2962 / 82-0
mail@oventrop.de
www.oventrop.de

PRODUCTS RvA C 002

Certification process consists of initial and regular assessment of:
- **quality system**
- **product**

Thermostatic regulating valves

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

Model Aquastrom T plus DN 15, IG*IG
Model Aquastrom T plus DN 15, AG*AG

Model Aquastrom T plus DN 20, IG*IG
Model Aquastrom T plus DN 20, AG*AG

Model Aquastrom T plus DN 25, IG*IG
Model Aquastrom T plus DN 25, AG*AG

Model Aquastrom VT DN 15, IG*IG
Model Aquastrom VT DN 15, AG*AG
Model Aquastrom VT DN 15, Press fitting 15 mm
Model Aquastrom VT DN 15, Press fitting 18 mm

Model Aquastrom VT DN 20, IG * IG
Model Aquastrom VT DN 20, AG *AG
Model Aquastrom VT DN 20, Press fitting 22 mm

Fitness for contact with drinking water

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" (“Materials and chemicals in the supply of drinking water and warm tap water Regulation”; published in the Government Gazette).
These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed ‘appendix hygienic aspects’ to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA ",
Place of the mark: On the body or adjusting device

Compulsory specifications:

- Direction of flow;
- Manufacturers mark
- Nominal diameter (DN);

Method of marking:

- Non-erasable;
- visible after assembly.

APPLICATION AND USE

Products are intended for application in circulation systems in tap water installations with a static water pressure of maximum 1000 kPa and a maximum water temperature of 90°C.
After regulating a pre-adjusted minimum temperature upstream will be maintained with conservation of the hydraulic balance.

Thermostatic regulating valves

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Oventrop GmbH & Co. KG

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier’s processing guidelines for the proper storage and transport methods.