DIN CERTCO
Gesellschaft für Konformitätsbewertung mbH

CERTIFICATE

Certificate holder	**Oventrop GmbH & Co. KG** **Paul-Oventrop-Str. 1** **59939 Olsberg** **GERMANY**
Production facility	Olsberg/Brilon
Product	Solar collectors
Type, Model	OKP-10, OKP-20
Testing basis	DIN EN 12975-1:2011-01 DIN EN ISO 9806:2018-04 SOLAR KEYMARK Scheme Rules (2020-06)
Mark of conformity	
Registration No.	011-7S524 R
Valid until	2025-10-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2020-10-13

Robert Zorn M.Sc.
Managing Director

DAkkS
Deutsche Akkreditierungsstelle
D-ZE-11125-01-00

DIN CERTCO
Gesellschaft für Konformitätsbewertung mbH

ANNEX

Certificate	011-7S524 R dated 2020-10-13
Technical Data	See data sheet, part of the test report of 2020-10-05 Note(s): - The freeze resistance test according to DIN EN ISO 9806, clause 14 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appopriate frost protection mixtures or with appropriate frost protection controller.
Testing laboratory/ Inspection body	Fraunhofer-Institut für Solare Energiesysteme ISE Heidenhofstr. 2 79110 Freiburg GERMANY
Test report(s)	KTB: 2020-01, KTB: 2020-09 dated 2020-10-05