

We, **Oventrop GmbH & Co. KG**

Paul-Oventrop-Str.1  
D-59939 Olsberg

hereby declare at sole responsibility that the following products to which this declaration refers, correspond to the standards and technical specifications

**DIN EN 13828, DIN 50930- 6**

Product


**Ball valve for potable water "Optibal TW"**

| Item no.  | DN<br>[mm] | Max. operating<br>pressure $p_s$ | Operating<br>temperature<br>range $t_s$ | CE- Marking |
|-----------|------------|----------------------------------|-----------------------------------------|-------------|
| 420 88 52 | 15         | 10 bar<br>(PN 10)                | 0°C up to 90°                           | No          |
| 420 88 53 | 15         |                                  |                                         |             |
| 420 88 54 | 20         |                                  |                                         |             |
| 420 88 55 | 25         |                                  |                                         |             |
| 420 88 56 | 32         |                                  |                                         |             |
| 420 88 57 | 40         |                                  |                                         |             |
| 420 88 58 | 50         |                                  |                                         |             |

Monitoring quality management system:  
Surveillance during production:

DQS 000211 QM  
OVENTROP

Olsberg, 09.12.2010

i.V.   
Dr. Ing. Foitzik  
Technical director

i.A.   
Dipl.-Ing. Coerdts  
Project manager