

CERTIFICATE

Certificate holder **Oventrop GmbH & Co. KG**
Paul-Oventrop-Str. 1
59939 Olsberg
GERMANY

Production facility Olsberg/Brilon

Product Solar collectors

Type, Model OKP-10, OKP-20

Testing basis DIN EN 12975-1:2011-01
DIN EN ISO 9806:2018-04
SOLAR KEYMARK Scheme Rules (2020-06)

Mark of conformity

Registration No. 011-7S524 R

Valid until 2025-10-31

Right of use

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

2020-10-13


Robert Zorn M.Sc.

Managing Director

ANNEX

Page 1 of 1

Certificate

011-7S524 R dated 2020-10-13

Technical Data

See data sheet, part of the test report of 2020-10-05

Note(s):

- The freeze resistance test according to DIN EN ISO 9806, clause 14 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures or with appropriate frost protection controller.

**Testing laboratory/
Inspection body**

Fraunhofer-Institut für
Solare Energiesysteme ISE
Heidenhofstr. 2
79110 Freiburg
GERMANY

Test report(s)

KTB: 2020-01, KTB: 2020-09 dated 2020-10-05

