

We, **Oventrop GmbH & Co. KG**

Paul-Oventrop-Str 1  
D-59939 Olsberg

hereby declare at sole responsibility that the following products  
to which this certificate refers, correspond to  
**DIN 50930-6:2001-8**

Product

**Thermostatic mixing valve  
"Brawa Mix"**


| Item no.  | DN<br>[mm] | Max. working<br>pressure p <sub>s</sub> | setting range<br>t <sub>E</sub> | Working temperature<br>range t <sub>s</sub> |
|-----------|------------|-----------------------------------------|---------------------------------|---------------------------------------------|
| 130 03 06 | 20         | 10 bar<br>(PN10)                        | +30° +65°C                      | +2°C – +90°C                                |
| 130 03 08 | 25         |                                         |                                 |                                             |
| 130 03 10 | 32         |                                         |                                 |                                             |
| 130 03 51 | 20         |                                         | +35° +50°C                      |                                             |
| 130 03 52 | 20         |                                         |                                 |                                             |
| 130 02 00 | 20         |                                         | +30° +70°C                      |                                             |
| 130 02 51 | 20         |                                         |                                 |                                             |

Monitoring quality management system:  
Surveillance during production:

DQS 000211 QM  
OVENTROP


Olsberg, den 27.07.2008

i.V.



Dr Ing. Foitzik  
Technical director

i.A.



Dipl.-Ing. Böning  
Project manager